

Anybus[®] CompactCom[™] B40
HARDWARE DESIGN GUIDE

HMSI-27-230
Version 3.6
Publication date 2024-12-17

Important User Information

Disclaimer

The information in this document is for informational purposes only. Please inform HMS Networks of any inaccuracies or omissions found in this document. HMS Networks disclaims any responsibility or liability for any errors that may appear in this document.

HMS Networks reserves the right to modify its products in line with its policy of continuous product development. The information in this document shall therefore not be construed as a commitment on the part of HMS Networks and is subject to change without notice. HMS Networks makes no commitment to update or keep current the information in this document.

The data, examples and illustrations found in this document are included for illustrative purposes and are only intended to help improve understanding of the functionality and handling of the product. In view of the wide range of possible applications of the product, and because of the many variables and requirements associated with any particular implementation, HMS Networks cannot assume responsibility or liability for actual use based on the data, examples or illustrations included in this document nor for any damages incurred during installation of the product. Those responsible for the use of the product must acquire sufficient knowledge in order to ensure that the product is used correctly in their specific application and that the application meets all performance and safety requirements including any applicable laws, regulations, codes and standards. Further, HMS Networks will under no circumstances assume liability or responsibility for any problems that may arise as a result from the use of undocumented features or functional side effects found outside the documented scope of the product. The effects caused by any direct or indirect use of such aspects of the product are undefined and may include e.g. compatibility issues and stability issues.

Copyright © 2024 HMS Networks

Contact Information

Postal address:

Box 4126

300 04 Halmstad, Sweden

E-Mail: info@hms.se

Table of Contents

1. Preface	1
1.1. About this Document	1
1.2. Related Documents	1
1.3. Document history	1
1.4. Document Conventions	1
1.5. Document Specific Conventions	3
1.5.1. PIN Types	3
1.6. Trademark Information	3
2. About the Anybus CompactCom B40-1	4
2.1. General Information	4
2.2. Features	5
3. Host Interface	6
3.1. Overview	6
3.1.1. Parallel Interface, 8-bit or 16-bit	6
3.1.2. SPI	6
3.1.3. Stand-Alone Shift Register Interface	6
3.1.4. Serial Interface (UART)	7
3.1.5. LED Interface	7
3.1.6. Reduced Media-Independent Interface (RMII)	7
3.2. Host Application Connector	8
3.2.1. Pin Overview	10
3.2.2. Power Supply Pins	12
3.2.3. LED Interface / D8–D15 (Data Bus)	12
3.2.4. Settings / Sync	13
3.2.5. IRQ (Interrupt Request)	15
3.2.6. RESET (Reset Input)	16
3.2.7. RMII — Reduced Media-Independent Interface	18
3.3. Parallel Interface Operation	19
3.3.1. General Description	19
3.3.2. Pin Usage in 8-bit Parallel Mode	20
3.3.3. Pin Usage in 16-bit Parallel Mode	23
3.3.4. Memory Access Read Timing	25
3.3.5. Memory Access Write Timing	26
3.4. SPI Operation	27
3.4.1. General Description	27
3.4.2. Pin Usage in SPI Mode	28
3.4.3. SPI Interface Signals	30
3.5. Stand-alone Shift Register	33
3.5.1. General Information	33
3.5.2. Pin Usage in Stand-Alone Shift Register Mode	34
3.5.3. Timing	38
3.5.4. Basic Shift Register Circuit	39
3.5.5. Reset Circuit Example	40
3.5.6. DIP Switches Example	40
3.6. UART Operation	41
3.6.1. General Description	41
3.6.2. Pin Usage in Serial Mode	42
3.6.3. Baud Rate Accuracy	44
4. Network Connector	45

4.1. Overview	47
4.2. Power Supply Pins	48
4.3. How to Connect Unused Network Connector Pins	48
4.4. Ethernet Based Networks (Copper)	49
4.5. Ethernet Fiber Optic Networks	50
4.5.1. Rx Channel Design Requirements	51
4.5.2. SD Channel Design Requirements	52
4.6. DeviceNet	52
4.7. PROFIBUS	53
4.8. CC-Link	53
4.9. LED Indicators	54
4.9.1. Ethernet, 1000 Mbit	55
5. EMC	56
5.1. General	56
5.2. Bulk and Decoupling	58
5.3. Reset Signal	58
6. Black Channel/Safety Interface	59
Appendix A. Mechanical Specification	60
1. Anybus CompactCom B40-1	60
2. Connector Board for PROFIBUS and CANopen	61
3. Connector Board for Copper Based Ethernet	62
4. Connector Board for Fiber Optic Ethernet	63
5. Connector Board for CC-Link and DeviceNet	64
6. Footprints	65
6.1. Anybus CompactCom B40-1	65
6.2. Network Connector Board	66
7. Height Restrictions	66
8. Front Plate Restrictions	67
9. Assembly	68
Appendix B. Technical Specification	70
1. Environmental	70
1.1. Operating	70
1.2. Storage	70
1.3. Humidity	70
2. Shock and Vibration	70
2.1. Shock	70
2.2. Sinusoidal Vibration	70
3. Electrical Characteristics	70
3.1. Operating Conditions	71
4. Regulatory Compliance	71
4.1. EMC Compliance (CE)	71
4.2. UL/c-UL Compliance	72
Appendix C. How to Inactivate Ethernet Port 2 (Industrial Ethernet)	73
Appendix D. Implementation Examples	74
1. General	74
2. SPI	74
3. 16-bit Parallel	75
4. 8-bit Parallel	76
5. Serial	77

- 6. Network Status LED Outputs (LED[1A...4B]) 77
- 7. Power Supply Considerations 79
 - 7.1. General 79
 - 7.2. Bypass Capacitance 80
 - 7.3. 3.3 V Regulation 80
- Appendix E. Design Examples, Network Interface 81**
 - 1. Recommendations 82
 - 2. PCB Layout 83
 - 3. Network Interface Examples 84

This page is intentionally left blank.

1. Preface

1.1. About this Document

This document is intended to provide a good understanding of how to use the Anybus CompactCom B40-1.

The reader of this document is expected to be familiar with hardware design and communication systems in general. For additional information, documentation, support etc., please visit the support website at www.hms-networks.com.

1.2. Related Documents

Document	Author	Document ID
Anybus CompactCom 40 Software Design Guide	HMS	HMSI-216-125
Anybus CompactCom 40 Network Guides	HMS	
Anybus CompactCom Host Application Implementation Guide	HMS	HMSI-27-334

1.3. Document history

Version	Date	Description
1.23	2015-09-03	Last FM version.
2.0	2016-03-10	Moved from FM to XML Misc. updates
2.1	2016-12-07	Added information for Anybus CompactCom B40 CC-Link IE Field Minor corrections and updates
3.0	2017-09-12	Added content to make the design guide independent of the M40 HWDG Added new example schematics Added BACnet/IP
3.1	2018-03-09	Updated section on DIP1 and DIP2 usage Added section on EMC Misc corrections
3.2	2018-05-25	Corrected pinnings for 8-bit parallel Misc corrections
3.3	2018-10-23	Minor corrections
3.4	2019-02-27	Updated for CANopen release Rebranded
3.5	2024-08-16	Minor updates and corrections
3.6	2024-12-17	Updated EMC information Minor updates

1.4. Document Conventions

Lists

Numbered lists indicate tasks that should be carried out in sequence:

1. First do this
2. Then do this

Bulleted lists are used for:

- Tasks that can be carried out in any order

- Itemized information

User Interaction Elements

User interaction elements (buttons etc.) are indicated with bold text.

Program Code and Scripts

Program code and script examples

Cross-References and Links

Cross-reference within this document: [Document Conventions \(page 1\)](#)

External link (URL): www.hms-networks.com

Safety Symbols



DANGER

Instructions that must be followed to avoid an imminently hazardous situation which, if not avoided, will result in death or serious injury.



WARNING

Instructions that must be followed to avoid a potential hazardous situation that, if not avoided, could result in death or serious injury.



CAUTION

Instruction that must be followed to avoid a potential hazardous situation that, if not avoided, could result in minor or moderate injury.



IMPORTANT

Instruction that must be followed to avoid a risk of reduced functionality and/or damage to the equipment, or to avoid a network security risk.

Information Symbols



NOTE

Additional information which may facilitate installation and/or operation.



TIP

Helpful advice and suggestions.

1.5. Document Specific Conventions

- The terms “Anybus” or “module” refers to the Anybus CompactCom module.
- The terms “host” or “host application” refer to the device that hosts the Anybus CompactCom hardware or software.
- Hexadecimal values are written in the format NNNNh or 0xNNNN, where NNNN is the hexadecimal value.
- A byte always consists of 8 bits.
- All dimensions in this document have a tolerance of ± 0.10 mm unless otherwise stated.
- Outputs are TTL compliant unless otherwise stated.
- Signals which are “pulled to GND” are connected to GND via a resistor.
- Signals which are “pulled to 3V3” are connected to 3V3 via a resistor.
- Signals which are “tied to GND” are directly connected to GND,
- Signals which are “tied to 3V3” are directly connected to 3V3.

1.5.1. PIN Types

The pin types of the connectors are defined in the table below. The pin type may be different depending on which mode is used.

Pin type	Definition
I	Input
O	Output
I/O	Input/Output (bidirectional)
OD	Open Drain
Power	Pin connected directly to the pluggable brick power supply, GND or 3V3

1.6. Trademark Information

Anybus® is a registered trademark of HMS Industrial Networks.



EtherCAT® is a registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.

All other trademarks are the property of their respective holders.

2. About the Anybus CompactCom B40-1

2.1. General Information

The Anybus CompactCom B40-1 concept is developed for applications where the standard Anybus CompactCom M40 cannot be used. The brick consists of a board with network connectivity functionality, where the customer provides the physical network interface, including network connectors. There are also available interface boards for several networks, providing network connectors and physical interface.

All Anybus CompactCom B40-1 share footprint and electrical interface. The brick has two connectors that provide communication with the host application board. The host application connector provides an interface between the host application and the brick, while the network connector provides network access. This enables full Anybus CompactCom functionality for all applications without loss of network compatibility or environmental characteristics.

All dimensions expressed in this document are stated in millimeters and have a tolerance of ± 0.10 mm unless stated otherwise.

For general information about the Anybus CompactCom 40 platform, consult the Anybus CompactCom 40 Software Design Guide.



IMPORTANT

This is a class A product. In a domestic environment, this product may cause radio interference in which case the user may be required to take adequate measures.

This product contains ESD (Electrostatic Discharge) sensitive parts that may be damaged if ESD control procedures are not followed. Static control precautions are required when handling the product. Failure to observe this may cause damage to the product.

2.2. Features

- Hardware support for triple buffered process data, which increases performance
- Supports synchronization for selected industrial networks
- Black channel interface, offering a transparent channel for safety communication for selected networks
- Low latency
- Integrated protocol stack handling (where applicable)
- Control pins for status indications according to each network standard (where applicable)
- Separate network connector boards available
- Firmware upgradable (FLASH technology)
- 3.3 V design
- 8-bit and 16-bit parallel modes
- SPI mode
- Shift register mode
- UART/Serial mode
- Transparent Ethernet functionality
- Precompliance tested for network conformance (where applicable)
- Precompliance tested for CE & UL. Contact HMS Industrial Networks for further information



IMPORTANT

All Anybus CompactCom B40-1 are precertified for network conformance, where applicable. This precertification is done to ensure that the end product can be certified. Contact HMS Industrial Networks for further information.

3. Host Interface

This chapter describes the low level properties of the Anybus CompactCom interface.

3.1. Overview

The Anybus CompactCom has five different host communication interfaces, corresponding to different operating modes. The figure below illustrates the basic properties of these interfaces as well as various I/O and control signals, and how they relate to the host application. Only one interface at a time can be active.




Figure 1.

Please note that only one communication interface at a time is available. Which one is decided at startup.

3.1.1. Parallel Interface, 8-bit or 16-bit

From an external point of view, the parallel interface is a common 8-bit or 16-bit parallel slave port interface, which can easily be incorporated into any microprocessor based system that has an external address/data bus. Generally, implementing this type of interface is comparable to implementing an 8-bit or 16-bit wide SRAM. Additionally, the parallel interface features an interrupt request line, allowing the host application to service the module only when actually needed.

3.1.2. SPI

The Serial Peripheral Interface (SPI) is a synchronous serial link. It operates in full duplex mode and devices communicate in main device/sub device mode where the Anybus CompactCom modules always act as sub devices. The interface can provide much higher performance than the serial interface, but not as high as the parallel interface.

3.1.3. Stand-Alone Shift Register Interface

In this mode the Anybus CompactCom B40-1 operates stand-alone, with no host processor. Process data is communicated to the shift registers on the host.

3.1.4. Serial Interface (UART)

The serial interface is provided for backward compatibility with the Anybus CompactCom 30. The interface is event based, and has lower performance than the SPI and parallel modes. For more information about the serial interface, see the Anybus CompactCom Hardware Design Guide for the 30 series.

Please note that the Anybus CompactCom B40-1 is not backward compatible to the Anybus CompactCom B30 hardware wise.

3.1.5. LED Interface

The status of the network LEDs is available as follows:

- As LED output signals on the network interface connector. These signals are able to drive a LED directly and are available for all networks and operating modes. (Recommended)
- As LED output signals on the host interface connector for all operating modes except 16-bit parallel mode. These signals are not able to drive a LED directly.
- In the LED status register for all modes, see Anybus CompactCom 40 Software Design guide for more information.

3.1.6. Reduced Media-Independent Interface (RMII)

This interface is used for Transparent Ethernet, where Industrial Ethernet communication is handled by the Anybus CompactCom and other Ethernet communication is routed to the host application. 16-bit parallel mode and the LED Interface signals are not available in the host application connector when Transparent Ethernet is enabled. The LED signals are still available on the network connector of the Anybus CompactCom B40-1.

See [RMII — Reduced Media-Independent Interface \(page 18\)](#) for more information.

3.2. Host Application Connector

The host application connector provides an interface between the host application and the Anybus CompactCom B40-1.




Figure 2.

The connector is implemented by a standard 1.27 mm 56 pin header surface mounted to the bottom side of the PCB.




Figure 3.

The pictures shows the pinning of the mating connector on the host application seen from the top.

GND	2	☐	☐	1	3V3
A0/ $\overline{\text{WEH}}$ /DIP1_0	4	☐	☐	3	$\overline{\text{RESET}}$
A2/DIP1_2	6	☐	☐	5	A1/DIP1_1
GND	8	☐	☐	7	A3/DIP1_3
A5/DIP1_5	10	☐	☐	9	A4/DIP1_4
A7/DIP1_7	12	☐	☐	11	A6/DIP1_6
GND	14	☐	☐	13	A8/ $\overline{\text{LD}}$ / $\overline{\text{SS}}$
A10/D0/MISO	16	☐	☐	15	A9/SCLK
GND	18	☐	☐	17	A11/DI/MOSI
A13/ASI_TX	20	☐	☐	19	A12/ASI_RX
D6/DIP2_6	22	☐	☐	21	D7/DIP2_7
GND	24	☐	☐	23	D5/DIP2_5
D3/DIP2_3	26	☐	☐	25	D4/DIP2_4
GND	28	☐	☐	27	D2/DIP2_2
MD0	30	☐	☐	29	D1/DIP2_1
OM0	32	☐	☐	31	D0/DIP2_0
GND	34	☐	☐	33	OM1
$\overline{\text{CS}}$	36	☐	☐	35	OM2
$\overline{\text{IRQ}}$ /PA	38	☐	☐	37	$\overline{\text{WE}}$ / $\overline{\text{WEL}}$ /CT
GND	40	☐	☐	39	$\overline{\text{OE}}$
$\overline{\text{LED4B}}$ /D14	42	☐	☐	41	$\overline{\text{LED4A}}$ /D15
GND	44	☐	☐	43	$\overline{\text{LED3A}}$ /D13
LED2A/D11	46	☐	☐	45	$\overline{\text{LED3B}}$ /D12
LED1A/D9	48	☐	☐	47	LED2B/D10
GND	50	☐	☐	49	LED1B/D8
TX/ASI_TX/OM3	52	☐	☐	51	RX/ASI_RX
MI0/SYNC	54	☐	☐	53	MI1
GND	56	☐	☐	55	3V3

Figure 4.

See [Pin Overview \(page 10\)](#) for information on how each pin is used in the different modes.

3.2.1. Pin Overview

Depending on operating mode, the pins have different names and different functionality. Presented below is an overview of all pins except GND and 3V3.

The pin types of the connector are defined in [PIN Types \(page 3\)](#). The pin type may be different depending on which mode is used.

**NOTE**

The ASI (Anybus Safety Interface) signals are used to connect a safety module to the safety interface of an Anybus CompactCom 40-series module.

**IMPORTANT**

The pin numbers of the Anybus CompactCom B40 (brick) host application connector are different from those of the Anybus CompactCom M40 (module) host application connector.

Pin	Signal Name					Type	Notes
	Serial Mode	SPI Mode	8-bit Mode	16-bit Mode	Shift Register Mode		
4	DIP1_0	DIP1_0	A0	WEH	DIP1_0	I	
5	DIP1_1	DIP1_1	A1	A1	DIP1_1	I	
6	DIP1_2	DIP1_2	A2	A2	DIP1_2	I	
7	DIP1_3	DIP1_3	A3	A3	DIP1_3	I	
9	DIP1_4	DIP1_4	A4	A4	DIP1_4	I	
10	DIP1_5	DIP1_5	A5	A5	DIP1_5	I	
11	DIP1_6	DIP1_6	A6	A6	DIP1_6	I	
12	DIP1_7	DIP1_7	A7	A7	DIP1_7	I	
13		SS	A8	A8	LD	I/O	
15		SCLK	A9	A9	SCLK	O, I	
16		MISO	A10	A10	DO	O, I	
17		MOSI	A11	A11	DI	I	
19	ASI RX		A12	A12		I	
20	ASI TX		A13	A13		O, I	
31	DIP2_0	DIP2_0	D0	D0	DIP2_0	I, I/O	
29	DIP2_1	DIP2_1	D1	D1	DIP2_1	I, I/O	
27	DIP2_2	DIP2_2	D2	D2	DIP2_2	I, I/O	
26	DIP2_3	DIP2_3	D3	D3	DIP2_3	I, I/O	
25	DIP2_4	DIP2_4	D4	D4	DIP2_4	I, I/O	
23	DIP2_5	DIP2_5	D5	D5	DIP2_5	I, I/O	
22	DIP2_6	DIP2_6	D6	D6	DIP2_6	I, I/O	
21	DIP2_7	DIP2_7	D7	D7	DIP2_7	I, I/O	
49	LED1B	LED1B	LED1B	D8	LED1B	O, I/O	In modules supporting RMII, these pins are used for the RMII interface when this has been activated, see RMII — Reduced Media-Independent Interface (page 18).
48	LED1A	LED1A	LED1A	D9	LED1A	O, I/O	
47	LED2B	LED2B	LED2B	D10	LED2B	O, I/O	
46	LED2A	LED2A	LED2A	D11	LED2A	O, I/O	
45	LED3B	LED3B	LED3B	D12	LED3B	OD, I/O	
43	LED3A	LED3A	LED3A	D13	LED3A	OD, I/O	
42	LED4B	LED4B	LED4B	D14	LED4B	O, I/O	
41	LED4A	LED4A	LED4A	D15	LED4A	O, I/O	
37			WE	WEL	CT	I	
39			OE	OE		I	
36			CS	CS		I	
38		IRQ	IRQ	IRQ	PA	O	
51	RX	ASI RX	ASI RX	ASI RX	ASI RX	I	
52	TX / OM3	ASI TX / OM3	ASI TX / OM3	ASI TX / OM3	ASI TX / OM3	I/O	Strapping input with internal weak pull-up during powerup. To configure OM3, use an external pull-up/pull-down of 1.0 to 2.2 kΩ. The pin changes to output after powerup.
32	OM0	OM0	OM0	OM0	OM0	I	
33	OM1	OM1	OM1	OM1	OM1	I	
35	OM2	OM2	OM2	OM2	OM2	I	
54	MI0	MI0/SYNC	MI0/SYNC	MI0/SYNC	MI0/SYNC	O	Low at power-up and before reset release.
53	MI1	MI1	MI1	MI1	MI1	O	Tied to 3V.
30	MD0	MD0	MD0	MD0	MD0	O	Tied to GND.
3	RESET	RESET	RESET	RESET	RESET	I	

3.2.2. Power Supply Pins

Signal	Pin Type	Pin	Description
GND	Power	2, 8, 14, 18, 24, 28, 34, 40, 44, 50, 56	Ground. Power and signal ground reference.
3V3	Power	1, 55	3.3 V power supply.

3.2.3. LED Interface / D8–D15 (Data Bus)

Signal Name	Pin Type	Pin	Description, LED Interface	Description, Data Bus
LED1A / D9	O / I/O	48	LED 1 Indication A • Green	D9 Data Bus • "D9" in 16-bit parallel mode.
LED1B / D8	O / I/O	49	LED 1 Indication B • Red	D8 Data Bus • "D8" in 16-bit parallel mode.
LED2A / D11	O / I/O	46	LED 2 Indication A • Green	D11 Data Bus • "D11" in 16-bit parallel mode.
LED2B / D10	O / I/O	47	LED 2 Indication B • Red	D10 Data Bus • "D10" in 16-bit parallel mode.
LED3A / D13	OD / I/O	43	LED 3 Indication A • Green • Mainly used for link/activity on network port 1 on the Ethernet modules. Pin is open-drain to maintain backward compatibility with existing applications, where this pin may be tied to GND.	D13 Data Bus • "D13" in 16-bit parallel mode.
LED3B / D12	OD / I/O	45	LED 3 Indication B • Yellow or red, depending on network • Mainly used for link/activity on network port 1 on the Ethernet modules (yellow). Pin is open-drain to maintain backward compatibility with existing applications, where this pin may be tied to GND.	D12 Data Bus • "D12" in 16-bit parallel mode.
LED4A / D15	O / I/O	41	LED 4 Indication A • Green • Mainly used for link/activity on network port 2 on the Ethernet modules.	D15 Data Bus • "D15" in 16-bit parallel mode.
LED4B / D14	O / I/O	42	LED 4 Indication B • Yellow or red, depending on network • Mainly used for link/activity on network port 2 on the Ethernet modules (yellow)	D14 Data Bus • "D14" in 16-bit parallel mode.



NOTE

The LED signals are also available on the network connector as active high push/pull signals. Those signals are easier to use for LEDs.

3.2.4. Settings / Sync

Signal Name	Pin Type	Pin	Description
OM0 OM1 OM2 OM3 (ASI TX) (TX)	I I I I (Used as OM3 during power up)	32 33 35 52	Operating Mode Used to select interface and baud rate, see below.
MI0 / SYNC MI1	O O	54 53	Module Identification MI0 and MI1 can be used by the host application to determine what type of Anybus CompactCom that is connected. SYNC On networks that support synchronous communication, a periodic synchronization pulse is provided on the SYNC output. The SYNC pulse is also available as a maskable interrupt using the IRQ signal.
MD0	O	30	Module Detection This signal can be used by the host application to determine that an Anybus CompactCom is inserted into the slot, see Module Detection (page 14) . The signal is connected directly to GND on the Anybus CompactCom.
ASI RX ASI TX	I O	51 52 UART operation: 19 20	Black Channel Communication These signals can be connected to a safety module, e.g. to IXXAT Safe T100 to provide a safe channel for black channel communication. If not used, pin 51 (for UART operation pin 19) should be pulled to 3V3.
RX TX	I O	51 52	Serial Communications Signals

Operating Modes

These inputs select the interface that should be used to exchange data (SPI, stand-alone shift register, parallel or serial) and, if the serial interface option is used, the operating baud rate. The state of these signals is sampled once during startup, i.e. any changes require a reset in order to have effect.

OM3	OM2	OM1	OM0	Operating Mode
LOW	LOW	LOW	LOW	Reserved
LOW	LOW	LOW	HIGH	SPI
LOW	LOW	HIGH	LOW	Stand-alone shift register
LOW	LOW	HIGH	HIGH	Reserved
LOW	HIGH	LOW	LOW	Reserved
LOW	HIGH	LOW	HIGH	Reserved
LOW	HIGH	HIGH	LOW	Reserved
LOW	HIGH	HIGH	HIGH	16-bit parallel
HIGH	LOW	LOW	LOW	8-bit parallel
HIGH	LOW	LOW	HIGH	Serial 19.2 kbps
HIGH	LOW	HIGH	LOW	Serial 57.6 kbps
HIGH	LOW	HIGH	HIGH	Serial 115.2 kbps
HIGH	HIGH	LOW	LOW	Serial 625 kbps
HIGH	HIGH	LOW	HIGH	Reserved
HIGH	HIGH	HIGH	LOW	Reserved
HIGH	HIGH	HIGH	HIGH	Service Mode

LOW = V_{IL}

HIGH = V_{IH}



NOTE

These signals must be stable prior to releasing the RESET signal. Failure to observe this may result in faulty behavior.

Module Detection

This signal is internally connected to GND, and can be used by the host application to detect whether a module is present or not. When connecting an external pull-up resistor, a low signal indicates that a module is present.

If not used, leave this signal unconnected.

Module Identification

These signals indicate which type of module that is connected. It is recommended to check the state of these signals before accessing the module.

MI1	MI0	Module Type
LOW	LOW	Active Anybus CompactCom 30
LOW	HIGH	Passive Anybus CompactCom
HIGH	LOW	Active Anybus CompactCom 40
HIGH	HIGH	Customer specific

LOW = V_{OL}

HIGH = V_{OH}



NOTE
On modules supporting “SYNC”, MI0 is used as a SYNC signal during operation. MI0 should only be sampled by the application during the time period from power up to the end of SETUP state.

3.2.5. IRQ (Interrupt Request)

Signal Name	Pin Type	Pin	Description
IRQ	O	38	Interrupt Request Active low interrupt signal.

The use of this signal is optional but highly recommended. Even if the host application lacks interrupt capabilities, it is recommended to connect this signal to an input port to simplify software design.

This signal must be pulled to 3V3 on the host application side to prevent spurious interrupts during startup.

3.2.6. RESET (Reset Input)

Signal Name	Pin Type	Pin	Description
RESET	I	3	Reset Used to reset the module.

The master reset input is active low. It must be connected to a host application controllable output pin in order to handle the power up sequence, voltage deviations and to be able to support network reset requests. If the brick is used in stand-alone mode, with no host processor, a separate reset circuit can be used, see [Reset Circuit Example \(page 40\)](#).

The brick does not feature any internal reset regulation. To establish a reliable interface, the host application is solely responsible for resetting the module when the supply voltage is outside the specified range.

Power Up




Figure 5.

Powerup time limits are given in the table below:

Symbol	Min.	Max.	Definition
t_A	-	-	Time until the power supply is stable after power-on; the duration depends on the power supply design of the host application and is thus beyond the scope of this document.
t_B	1 ms	-	Safety margin.

Restart

The reset pulse duration must be at least 10 µs in order for the NP40 to properly recognize a reset.




Figure 6.

Symbol	Min.	Max.	Definition
t_c	10 µs	-	Reset pulse width.

3.2.7. RMII — Reduced Media-Independent Interface

In RMII enabled modules, the pins described in the table below are used for the RMII communication. They are set to tristate during startup, making it impossible to indicate e.g. exception during setup. When setup is complete, they are set to inputs/outputs according to the selected mode. See Anybus CompactCom 40 Software Design Guide for more information on mode selection.



IMPORTANT
The 16-bit parallel mode can not be used when RMII is enabled.

LED status will not be available when RMII is enabled.

Pin	Signal Name	Pin Type	Notes
49	RXD0	O	-
48	RXD1	O	-
47	RXDV	O	-
46		I	Not used (connect to external pull-down)
45	TXD0	I	-
43	TXD1	I	-
42	TXEN	I	-
41	CLK	I	-

Table 1. RMII Timing Details

Symbol	Parameter	Min.	Max.	Unit
tSU	TXD0, TXD1, TXEN data setup to CLK rising edge	4	-	ns
tHOLD	TXD0, TXD1, TXEN data hold from CLK rising edge	2	-	ns
tOD	RXD0, RXD1, RXDV output delay from CLK rising edge	2	12	ns




Figure 7.

3.3. Parallel Interface Operation

3.3.1. General Description

The parallel interface is based on an internal memory architecture, that allows the Anybus CompactCom B40 module to be interfaced directly as a memory mapped peripheral. The interface can be configured for 8-bit or 16-bit parallel operation. The access time is 30 ns.

Polled operation is possible, but at the cost of an overhead. For increased efficiency, an optional interrupt request signal (IRQ) can relieve the host application from polling for new information, thus increasing the performance. For more information, see [IRQ \(Interrupt Request\) \(page 15\)](#).

The parallel interface must be enabled using OM[0...3].

3.3.2. Pin Usage in 8-bit Parallel Mode

The parallel 8-bit interface uses the following signals:

Pin	Signal Name	Pin Type	Description/Comments
4	A0	I	A[0...3]: Mandatory address input signals.
5	A1		
6	A2		
7	A3		
9	A4		
10	A5		
11	A6		
12	A7		
13	A8		
15	A9		
16	A10		
17	A11		
19	A12		
20	A13		
31	D0	I/O	Standard bidirectional data bus.
29	D1		
27	D2		
26	D3		
25	D4		
23	D5		
22	D6		
21	D7		
49	LED1B	O	8-bit mode: LED functionality, see LED Interface (page 7) . When not used, LED1A, LED1B, LED2A, LED2B, LED4A and LED4B can be left unconnected. LED3A and LED3B are open-drain outputs and should, if not used, be pulled to 3V3 or tied to GND, depending on the requirements of the application.
48	LED1A	O	
47	LED2B	O	
46	LED2A	O	
45	$\overline{\text{LED3B}}$	OD	
43	$\overline{\text{LED3A}}$	OD	
42	$\overline{\text{LED4B}}$	O	
41	$\overline{\text{LED4A}}$	O	
37	$\overline{\text{WE}}$	I	Active low write signal or combined read/write signal.
39	$\overline{\text{OE}}$	I	Bus output enable; enables output on the data bus when low.
36	$\overline{\text{CS}}$	I	Bus chip select enable; enables parallel access to the module when low.
38	$\overline{\text{IRQ}}$	O	Active low Interrupt Request signal. Asserted by the Anybus CompactCom module. The use of this signal is optional but highly recommended. Even if the host application lacks interrupt capabilities, it is recommended to connect this signal to an input port to simplify software design. This signal must be pulled to 3V3 on the host application side to prevent spurious interrupts during startup.
32	OM0	I	Operating mode. Connect all three to GND for 8-bit parallel operating mode. For more information see Operating Modes (page 14) .
33	OM1		
35	OM2		
52	OM3 / ASI TX	O, I	Black channel output. See Black Channel/Safety Interface (page 59) . During startup the pin (with OM[0..2]) is used to define the operating mode of the module. Connect to external pull-up for 8-bit parallel operating mode, see Pin Overview (page 10) .
51	ASI RX	I	Black channel input. Tie to 3V3 if not used. See Black Channel/Safety Interface (page 59) .
54	MI0/SYNC	O	See Module Identification (page 15) .
53	MI1		
30	MD0	O	See Module Detection (page 14) .
3	$\overline{\text{RESET}}$	I	See RESET (Reset Input) (page 16) .



NOTE
There are no internal pull-up resistors on any of the signals above, except for OM3, which has an internal weak pull-up.

Function Table (CS, WE, OE, D[0...7])

CS	WE	OE	D[0...7] State	Comment
HIGH	X	X	High impedance	Module not selected.
LOW	LOW	X	Data Input (Write)	Data on D[0...7] is written to location selected by address bus.
LOW	HIGH	LOW	Data Output (Read)	Data from location selected by address bus is available on D[0...7].
LOW	HIGH	HIGH	High impedance	Module is selected, but D[0...7] is in a high impedance state.

X = don't care

LOW = V_{IL}

HIGH = V_{IH}

3.3.3. Pin Usage in 16-bit Parallel Mode

The parallel 16-bit interface uses the following signals:

Pin	Signal Name	Pin Type	Description/Comments
5	A1	I	A[1...13]: Mandatory address input signals. Selects source/target location.
6	A2		
7	A3		
9	A4		
10	A5		
11	A6		
12	A7		
13	A8		
15	A9		
16	A10		
17	A11		
19	A12		
20	A13		
31	D0	I/O	Standard bidirectional data bus.
29	D1		
27	D2		
26	D3		
25	D4		
23	D5		
22	D6		
21	D7		
49	D8		
48	D9		
47	D10		
46	D11		
45	D12		
43	D13		
42	D14		
41	D15		
4	$\overline{\text{WEH}}$	I	Write enable high byte.
37	$\overline{\text{WEL}}$	I	Write enable low byte.
39	$\overline{\text{OE}}$	I	Bus output enable; enables output on the data bus when low.
36	$\overline{\text{CS}}$	I	Bus chip select enable; enables parallel access to the module when low.
38	$\overline{\text{IRQ}}$	O	Active low Interrupt Request signal. Asserted by the Anybus CompactCom module. The use of this signal is optional but highly recommended. Even if the host application lacks interrupt capabilities, it is recommended to connect this signal to an input port to simplify software design. This signal must be pulled to 3V3 on the host application side to prevent spurious interrupts during startup.
32	OM0	I	Operating mode. Connect all three to 3V3 for 16-bit parallel operating mode. For more information see Operating Modes (page 14) .
33	OM1		
35	OM2		
54	MI0/SYNC	O	See Module Identification (page 15) .
53	MI1		
52	OM3 / ASI TX	O, Strap	Black channel output. See Black Channel/Safety Interface (page 59) . During startup the pin (with OM[0..2]) is used to define the operating mode of the module. Connect to pull-down for 16-bit parallel operating mode, see Pin Overview (page 10) .
51	ASI RX	I	Black channel input. Connect to 3V3 if not used. See Black Channel/Safety Interface (page 59) .
30	MD0	O	See Module Detection (page 14) .
3	$\overline{\text{RESET}}$	I	See RESET (Reset Input) (page 16) .

The A0 signal is not needed in 16-bit parallel operating mode, as 16 bits are addressed instead of 8 bits. If there is need for writing one byte at the time signals $\overline{\text{WEH}}$ and $\overline{\text{WEL}}$ can be used to enable writing to the high or low byte respectively. If both are enabled both bytes are written.

Function Table (CS, $\overline{\text{WEL}}$, $\overline{\text{WEH}}$, $\overline{\text{OE}}$, D[0...15])

$\overline{\text{CS}}$	$\overline{\text{WEL}}$	$\overline{\text{WEH}}$	$\overline{\text{OE}}$	D[0...15] State	Comment
HIGH	X	X	X	High impedance	Module not selected.
LOW	LOW	HIGH	X	Data Input (Write)	Data on D[0...7] is written to low byte of location selected by address bus.
LOW	HIGH	LOW	X	Data Input (Write)	Data on D[8...15] is written to high byte of location selected by address bus.
LOW	LOW	LOW	X	Data Input (Write)	Data on D[0 ...15] is written to location selected by address bus.
LOW	HIGH	HIGH	LOW	Data Output (Read)	Data from location selected by address bus is available on D[0...15].
LOW	HIGH	HIGH	HIGH	High impedance	Module is selected, but D[0...15] is in a high impedance state.

X = don't care

LOW = V_{IL}

HIGH = V_{IH}

3.3.4. Memory Access Read Timing

The $\overline{\text{WE}}$ input signal must remain high during a read access. The timing diagram shows a burst read, but the timing applies for a single read as well. The Anybus CompactCom B40-1 has no setup or hold timing requirements on the address bus relative to $\overline{\text{CS}}$ during read operations. The only limitation on read setup and hold times is that the pingpong and powerup interrupt will be acknowledged if all address lines are high for 10-15 ns or more while $\overline{\text{CS}}$ is low.




Figure 8.

Symbol	Parameter	Min (ns)	Max (ns)
tRC	Read cycle time	30	-
tAA	Address valid to Data valid	-	30
tACS	$\overline{\text{CS}}$ low to Data valid	-	30
tAR	$\overline{\text{OE}}$ low to Data valid	-	15
tHZ	$\overline{\text{CS}}$ or $\overline{\text{OE}}$ high to output reached tristate	-	15
tDH	Data hold time	0	-

3.3.5. Memory Access Write Timing

It doesn't matter if the $\overline{OE}$ signal is low or high as long as $\overline{WE}$ is active (low). In 16 bit mode, the timing requirements of $\overline{WE}$ applies to both $\overline{WEL}$ and $\overline{WEH}$. The timing diagrams show a burst write but the timing applies for a single write as well. The first diagram shows write enable controlled write timing and the second shows chip select controlled write timing.




Figure 9.




Figure 10.

Symbol	Parameter	Min (ns)	Max (ns)
tWC	Write cycle time	30	-
tAS	Address valid before End-of-Write	15	-
tAH	Address valid after End-of-Write	0	-
tWP	$\overline{CS}$ and $\overline{WE}$ low pulse width	15	-
tDS	Data valid before End-of-Write	15	-
tDH	Data valid after End-of-Write	0	-
tWR	Write recovery time	10	-

3.4. SPI Operation

3.4.1. General Description

The SPI (Serial Peripheral Interface) bus is a synchronous serial data link standard which operates in full duplex mode.

The SPI interface is activated using the OM[0...3] inputs. See [Operating Modes \(page 14\)](#).

3.4.2. Pin Usage in SPI Mode

Presented below is an overview of all pins except GND and 3V3.

Pin	Signal Name	Pin Type	Description/Comments
4	DIP1_0	I	DIP switch. Usage defined by application.
5	DIP1_1	I	Readable through attribute #14 (Switch status) in Anybus Object, instance #1.
6	DIP1_2	I	Tie to GND if not used.
7	DIP1_3	I	
9	DIP1_4	I	
10	DIP1_5	I	
11	DIP1_6	I	
12	DIP1_7	I	
13	$\overline{SS}$	I	Sub device select. Active low.
15	SCLK	I	Serial Clock Input.
16	MISO	O	Main device input, sub device output. Input to the main device's shift register, and output from the sub device's shift register.
17	MOSI	I	Main device output, sub device input. Output from the main device's shift register, and input to the sub device's shift register.
19	(not used)	I	Tie to 3V3.
20		O, I	
31	DIP2_0	I	DIP switch. Usage defined by application.
29	DIP2_1	I	Readable through attribute #14 (Switch status) in Anybus Object, instance #1.
27	DIP2_2	I	Tie to GND if not used.
26	DIP2_3	I	
25	DIP2_4	I	
23	DIP2_5	I	
22	DIP2_6	I	
21	DIP2_7	I	
49	LED1B	O	LED interface. Gives access to LED indications. For more information, see LED Interface / D8–D15 (Data Bus) (page 12) ". When not used, LED1A, LED1B, LED2A, LED2B, LED4A and LED4B can be left unconnected. LED3A and LED3B are open-drain outputs and should, if not used, be pulled to 3V3 or tied to GND, depending on the requirements of the application.
48	LED1A	O	
47	LED2B	O	
46	LED2A	O	
45	$\overline{LED3B}$	OD	
43	$\overline{LED3A}$	OD	
42	$\overline{LED4B}$	O	
41	$\overline{LED4A}$	O	
37	(not used)	I	
39			
36			
38	$\overline{IRQ}$	O	Active low Interrupt Request signal. Asserted by the Anybus CompactCom module. The use of this signal is optional but highly recommended. Even if the host application lacks interrupt capabilities, it is recommended to connect this signal to an input port to improve the startup time. This signal must be pulled to 3V3 on the host application side to prevent spurious interrupts during startup.
32	OM0	I	Operating mode [OM2, OM1, OM0]: 0,0,1 for SPI operating mode. For more information see Operating Modes (page 14) .
33	OM1		
35	OM2		
52	OM3 / ASI TX	O, Strap	Black channel output. See Black Channel/Safety Interface (page 59) During startup the pin (with OM[0..2]) is used to define the operating mode of the module. Connect to external pull-down for SPI operating mode, see Pin Overview (page 10) .
51	ASI RX	I	Black channel input. Connect to 3V3 if not used. See Black Channel/Safety Interface (page 59) .
54	MI0/SYNC	O	See Module Identification (page 15) .
53	MI1		
30	MD	O	See Module Detection (page 14) .
3	$\overline{RESET}$	I	See RESET (Reset Input) (page 16) .

3.4.3. SPI Interface Signals

The SPI interface option uses three (optionally four) signals:

Signal	Description
SCLK	Serial Clock Input
MOSI	Main device output, sub device input. Output from the main device's shift register, and input to the sub device's shift register.
MISO	Main device input, sub device output. Input to the main device's shift register, and output from the sub device's shift register.
$\overline{SS}$	Sub device select (optional)

For increased efficiency, the interrupt request signal ($\overline{IRQ}$) is also available, allowing the host application to service the Anybus CompactCom only when necessary.

The Anybus CompactCom samples MOSI data on the rising edge of SCLK and propagates MISO data on the falling edge of SCLK, this is commonly known as SPI Mode 0.

Table 2. Summary of SPI Mode Support

SPI Mode	CPOL	CPHA	Supported by the Anybus CompactCom	Mode description
0	0	0	Only in 4-wire mode	Clock idles low; sample on first edge. Sample on rising edges.
1	0	1	No	Clock idles low; sample on second edge. Sample on falling edges.
2	1	0	No	Clock idles high; sample on first edge. Sample on falling edges.
3	1	1	Yes	Clock idles high; sample on second edge. Sample on rising edges.

4-Wire Mode

In 4-wire mode the $\overline{SS}$ signal is used to indicate the start and stop of an SPI transfer. In this mode the SCLK signal is allowed to be either idle high or idle low. This mode also allows multiple SPI sub devices on the same SPI bus, since Anybus CompactCom MISO is tri-stated when $\overline{SS}$ is high.

A 4-wire diagram example:




Figure 11.




Figure 12.

Item	Description	Min Value	Max Value
tSU	MOSI setup before SCK rising edge	10 ns	-
tHD	MOSI hold after SCK rising edge	10 ns	-
tDO	MISO change after SCK falling edge	0 ns	20 ns
tCL	SCK low period	20 ns	-
tCH	SCK high period	20 ns	-
tCL+tCH	SCLK period. Max. frequency supported is 20 MHz.	50 ns	-
tCSS	$\overline{SS}$ setup before first SCLK rising edge.	20ns	-
tCSH	$\overline{SS}$ hold after last SCLK rising edge.	20ns	-
tCSLZ	MISO valid after falling edge of $\overline{SS}$.	-	20ns
tCSHZ	MISO high-Z after rising edge of $\overline{SS}$.	-	20ns

3–Wire Mode

In 3-wire mode the $\overline{SS}$ signal must be tied low permanently, and the SCLK signal must be idle high. Multiple SPI sub devices on the same bus are not possible in this mode. The pluggabe brick detects start and stop of a transfer by monitoring SCLK activity.

There must be an idle period of at least 10 μs between two transfers in this mode, and the SCLK signal must never remain high for more than 5 μs during a transfer.

A 3-wire diagram example.




Figure 13.

SPI diagram and bit timing for 3-wire mode.




Figure 14.

Item	Description	Min Value	Max Value
tSU	MOSI setup before SCK rising edge	10 ns	-
tHD	MOSI hold after SCK rising edge	10 ns	-
tDO	MISO change after SCK falling edge	0 ns	20 ns
tCL	SCK low period	20 ns	-
tCH	SCK high period	20 ns	-
tCL+tCH	SCK period Max. frequency supported is 20 MHz.	50 ns	-

SPI Frame Format




Figure 15.

The bytes are transmitted with the most significant bit first. The byte order for non-byte frame elements is typically little endian. This means that the least significant byte is transmitted first. The CRC32 checksum is an exception as it is transmitted in big endian byte order (most significant byte first).

3.5. Stand-alone Shift Register

3.5.1. General Information

In this mode the Anybus CompactCom B40-1 operates stand-alone, with no host processor. Process data is communicated to shift registers on the host. The Anybus CompactCom B40-1 supports up to 32 registers in each direction, for a total of 256 bits of data.




Figure 16.

Even though the Anybus CompactCom B40-1 operates stand-alone, it is still possible to set host application attributes, via the use of the virtual attributes list. Some attributes are mandatory to implement in order to pass conformance test. See the Virtual Attributes section in the Anybus CompactCom 40 Software Design Guide for more information.

The Anybus CompactCom B40-1 will automatically detect the number of connected input and output shift registers. Every shift register will be represented by one UINT8 ADI (Application Data Instance). The input ADIs will be named “Input 0”, “Input 1”, etc. The output ADIs will be named “Output 0”, “Output 1”, etc.



NOTE

The ADI access descriptor values cannot be changed:

Input ADIs: 09h (Get access + Write process data mapping possible).

Output ADIs: 11h (Get access + Read process data mapping possible).

Bits are clocked out/in MSB first, on the positive side of SCLK. An active low load signal ($\overline{LD}$) loads all shift registers before and after a transfer.




Figure 17.

A fifth signal, PA, is high when the module is in active state, and low when the module is not. This signal can be used by the application to clear/set the output shift registers to default values when the module is not in active state.

3.5.2. Pin Usage in Stand-Alone Shift Register Mode

Presented below is an overview of all pins except GND and V_{DD} .

Pin	Signal Name	Pin Type	Description/Comments
4	DIP1_0	I	DIP switch node address / IP address. See DIP1 and DIP2 Pins Usage (page 37) .
5	DIP1_1	I	
6	DIP1_2	I	
7	DIP1_3	I	
9	DIP1_4	I	
10	DIP1_5	I	
11	DIP1_6	I	
12	DIP1_7	I	
13	$\overline{\text{LD}}$	O	Shift register load.
15	SCLK	O	Clock output.
16	DO	O	Serial data output to shift registers.
17	DI	I	Serial data input from shift registers.
19	(not used)	-	Leave unconnected.
20	(not used)	-	Leave unconnected.
31	DIP2_0	I	DIP switch baud rate / Device ID / station name. See DIP1 and DIP2 Pins Usage (page 37) .
29	DIP2_1	I	
27	DIP2_2	I	
26	DIP2_3	I	
25	DIP2_4	I	
23	DIP2_5	I	
22	DIP2_6	I	
21	DIP2_7	I	
49	LED1B	O	LED interface. Gives access to LED indications. For more information, see LED Interface / D8–D15 (Data Bus) (page 12) . When not used, LED1A, LED1B, LED2A, LED2B, LED4A and LED4B can be left unconnected. LED3A and LED3B are open-drain outputs and should, if not used, be pulled to 3V3 or tied to GND, depending on the requirements of the application.
48	LED1A	O	
47	LED2B	O	
46	LED2A	O	
45	$\overline{\text{LED3B}}$	OD	
43	$\overline{\text{LED3A}}$	OD	
42	$\overline{\text{LED4B}}$	O	
41	$\overline{\text{LED4A}}$	O	
37	CT	I	Center tap signal for shift register mode. The number of connected input and output shift registers will be detected using this signal.
38	PA	O	Process active signal for shift register mode. In a PROFINET shift register stand-alone application, the PA signal must be used to clear outputs, when the Anybus CompactCom B40-1 is not in state PROCESS ACTIVE. Otherwise it will not be possible to certify the final product. See the Anybus CompactCom 40 PROFINET IRT Network Guide for more information. The PA signal should be pulled low to make sure that noise/glitches does not affect the output shift registers while the Anybus CompactCom is in RESET, or not plugged in.
39	(not used)	-	Leave unconnected.
36	(not used)	-	Leave unconnected.
51	ASI RX	I	Black channel input. Connect to 3V3 if not used. See Black Channel/Safety Interface (page 59) .
52	ASI TX / OM3	O, Strap	Black channel output. See Black Channel/Safety Interface (page 59) . During startup the pin (with OM[0..2]) is used to define the operating mode of the module. Connect to external pull-down for shift register operating mode, see Pin Overview (page 10) .
32	OM0	I	Operating mode [OM2, OM1, OM0]: 0,1,0 for shift register operating mode. For more information see Operating Modes (page 14) .
33	OM1		
35	OM2		
54	MI0/SYNC	O	See Module Identification (page 15) .
53	MI1	O	
30	MD	O	See Module Detection (page 14) .

Pin	Signal Name	Pin Type	Description/Comments
3	RESET	I	See RESET (Reset Input) (page 16).

DIP1 and DIP2 Pins Usage

The use of the DIP1 and DIP2 pins is network specific. If used, they will be read during SETUP state. Thereafter, DIP switch changes will be sampled and written to the Network Configuration Object every 0.5 seconds.

DIP1 is linked to the Network Configuration Object, instance 1 (node address) or instance 3 (IP address). DIP2 is linked to the Network Configuration Object, instance 2 (baud rate) or instance 1 (Device ID, EtherCAT), or, in the case of PROFINET, linked to the PROFINET IO Object, instance 1, attribute 24.

See Network Configuration Object (04h) in the Anybus CompactCom 40 Software Design Guide for more information.

Network	DIP1 (linked to Network Configuration Object)	DIP2	Notes
DeviceNet	0 - 63 (Instance 1: Node address)	Value: 0 - 3 (Network Configuration Object, Instance 2: Baud Rate)	DIP2: Network Configuration Object, Instance 2: Baud Rate (125 kbps, 250 kbps, 500 kbps, Auto)
EtherCAT	1 - 254 (Instance 3: IP address)	0 - 255 (Network Configuration Object, Instance 1: Device ID)	If DIP1 is set to 0, saved values from instances 3 - 6 are used. If DIP1 is set to 255, DHCP is used for all settings. The DIP switches set the last byte of the IP address. Virtual attributes are used to configure the remaining part the IP address, as well as the subnetmask (Network Configuration Object, instance 4) and the gateway (instance 5).
EtherNet/IP	1 - 254 (Instance 3: IP address)	Not used	
Modbus-TCP	1 - 254 (Instance 3: IP address)	Not used	
Common Ethernet	1 - 254 (Instance 3: IP address)	Not used	
Ethernet POWERLINK	NMT_CS_BASIC_ETHERNET: 1 - 254 (Instance 3: IP address) NMT_CS_EPL_MODE: 1 - 239 (Instance 1: Node address)	Not used	If no POWERLINK traffic is seen at startup the module will enter the NMT_CS_BASIC_ETHERNET state after 5 seconds. In this state DIP1 is used for the IP address. As soon as the module detects POWERLINK traffic it will enter the NMT_CS_EPL_MODE super state. In this state DIP1 is used as the POWERLINK node address. In the NMT_CS_EPL_MODE state the IP address of the module is fixed to 192.168.100.yyy where yyy is the node address. Note that IT functionality can be disabled in the POWERLINK host application object. If that is done DIP1 is never used for the IP address.
PROFIBUS	0 - 126 (Instance 1: Node address)	Not used	-
PROFINET	1 - 254 (Instance 3: IP address)	Value: 1 — 255 (PROFINET IO object, Instance 1, attribute 24)	If DIP1 is set to 0, saved values from instances 3 - 6 are used. If DIP1 is set to 255, DHCP is used for all settings. The DIP1 to switches set the last byte of the IP address. Virtual attributes are used to configure the remaining part the IP address, as well as the subnetmask (Network Configuration Object, instance 4) and the gateway (instance 5). If DIP2 is set to 0, the value saved in the non volatile memory will be used. The DIP2 switches set the last three digits of the station name. see the Anybus CompactCom 40 PROFINET IRT Network Guide.
CC-Link	1 - 64 (Instance 1: Node address).	Value: 0 - 4 (Network Configuration Object, Instance 2: Baud Rate)	DIP1: Depending on number of stations used. An invalid value will generate a NACK on Setup Complete. DIP2: Network Configuration Object, Instance 2: Baud Rate (156 kbps, 625 kbps, 2.5 Mbps, 5 Mbps, 10 Mbps)
CC-Link IE Field	1 - 120 (Instance 1: Station Number).	1 - 239 (Instance 3: Network Number).	-
BACnet/IP	1 - 254 (Instance 3: IP address)	Not used	-
CANopen	0 - 127 (Instance 1: Node address)	Value: 0 - 9 (Network Configuration Object, Instance 2: Data Rate)	DIP2: Network Configuration Object, Instance 2: Data Rate

Unused DIP pins should be connected to ground (GND).

External pull-down resistors are needed if DIP switches are connected to the DIP1 and DIP2 pins, see [DIP Switches Example \(page 40\)](#).

3.5.3. Timing

The Anybus CompactCom B40-1 operates in 12.5 MHz in shift register mode.

Timing Diagram




Figure 18.

Abbreviations from the diagram above, explained, and timing details:

Item	Description	Min Value
tSUO	DO setup before SCK rising edge	20 ns
tHDO	DO hold after SCK rising edge	20 ns
tSUI	DI/CT setup before SCK rising edge	10 ns
tHDI	DI/CT hold after SCK rising edge	0 ns
tCH	SCK high period	35 ns
tCL	SCK low period	35 ns
tCH + tCL	SCK period	78 ns

The idle time between two transfers, i.e. when the $\overline{\text{LD}}$ signal is low, is at least 1 μs .

The cycle time range is typically 160 μs to 200 μs . However it is highly module and network dependent, and may differ from the defined range.

3.5.4. Basic Shift Register Circuit

The schematic below illustrates a basic shift register circuit.




Figure 19.

3.5.5. Reset Circuit Example

The reset circuit example in the figure, is a common 3.3 V supervisor. The main usage is to obtain a defined reset release delay after the voltage is switched on. The power supply has to provide a stable voltage within the interval 3.15–3.45 V.




Figure 20.

3.5.6. DIP Switches Example

Pull-down resistors are necessary if DIP switches are connected to the DIP inputs.




Figure 21.

3.6. UART Operation

3.6.1. General Description

The serial interface is a common asynchronous serial interface, which can easily be interfaced directly to a microcontroller or UART. It is provided for backward compatibility with the Anybus CompactCom 30 series.

The serial interface is activated using the OM[0...3] inputs, which also are used to select the operating baud rate, see [Operating Modes \(page 14\)](#).

Other communication settings are fixed to the following values:

Data bits: 8

Parity: None

Stop bits: 1

Communication settings are fixed to asynchronous, 8-N-1, with bit order LSB first and without hardware flow control signals.

**NOTE**

It is not possible to build a synchronous application in this mode.

3.6.2. Pin Usage in Serial Mode

Presented below is an overview of all pins except GND and 3V3.

Pin	Signal Name	Pin Type	Description/Comments
4	DIP1_0	I	DIP switch. Usage defined by application.
5	DIP1_1	I	Readable through attribute #14 (Switch status) in Anybus Object, instance #1.
6	DIP1_2	I	Connect directly to GND if not used.
7	DIP1_3	I	
9	DIP1_4	I	
10	DIP1_5	I	
11	DIP1_6	I	
12	DIP1_7	I	
13	(not used)	I	Connect directly to GND.
15		I	
16		O,I	
17	(not used)	I	Connect directly to 3V3.
19	ASI RX	I	See Black Channel/Safety Interface (page 59) . If not used, connect directly to 3V3.
20	ASI TX	O	See Black Channel/Safety Interface (page 59) . If not used, leave unconnected.
31	DIP2_0	I	DIP switch. Usage defined by application.
29	DIP2_1	I	Readable through attribute #14 (Switch status) in Anybus Object, instance #1.
27	DIP2_2	I	Connect directly to GND if not used.
26	DIP2_3	I	
25	DIP2_4	I	
23	DIP2_5	I	
22	DIP2_6	I	
21	DIP2_7	I	
49	LED1B	O	LED interface. Gives access to LED indications. For more information, see LED Interface / D8–D15 (Data Bus) (page 12) . When not used, LED1A, LED1B, LED2A, LED2B, LED4A and LED4B can be left unconnected.
48	LED1A	O	
47	LED2B	O	LED3A and LED3B are open-drain outputs and should, if not used, be pulled either to GND or to 3V3, depending on application.
46	LED2A	O	
45	LED3B	OD	
43	LED3A	OD	
42	LED4B	O	
41	LED4A	O	
37	(not used)	I	Connect directly to 3V3.
39		I	
36		I	
38	(not used)	O	Leave unconnected.
51	RX	I	Receive Input - Direction: Host application -> Anybus CompactCom - Idle state = High
52	TX / OM3	O, I	Transmit Output - Direction: Anybus CompactCom -> Host application - Idle state = High This pin doubles as OM3 strapping input on Anybus CompactCom M40 modules. Connect a pull-up resistor on the application for this pin in serial mode.
32	OM0	I	Operating mode [OM2, OM1, OM0]:
33	OM1		001 Serial 19.2 kbps
35	OM2		010 Serial 57.6 kbps
			011 Serial 115.2 kbps
			100 Serial 625 kbps
			For more information see Operating Modes (page 14) .

Pin	Signal Name	Pin Type	Description/Comments
54	MI0/SYNC	O	See Module Identification (page 15) .
53	MI1		
30	MD0	O	See Module Detection (page 14) .
3	RESET	I	See RESET (Reset Input) (page 16) .

**NOTE**

It is important to connect all signals correctly for proper functioning of the serial interface.

3.6.3. Baud Rate Accuracy

As with most asynchronous communication devices, the actual baud rate used on the Anybus CompactCom may differ slightly from the ideal baud rate.

The baud rate error of the pluggable brick is less than $\pm 1.5\%$. For proper operation, it is recommended that the baud rate accuracy in the host application lies within $\pm 1.5\%$ from the ideal value.

4. Network Connector

The network connector provides network access to the brick.




Figure 22.

The signals from the brick network connector can be directly routed to the (optional) connector board, which carries a network connector(s) identical or similar to the ones on the corresponding Anybus CompactCom M40 module.

Examples on how to design the network access circuitry, when not using the connector board, are shown in [Design Examples, Network Interface \(page 81\)](#).

The brick has a standard 1.27 mm 52 pin header surface mounted to the bottom side of the board as network interface.




Figure 23.

The pictures shows the pinning of the corresponding network connector on the host application board, seen from the top.

GND	2	□	□	1	3V3
B_1CEN/SDA	4	□	□	3	B_1P/RXP
GND	6	□	□	5	B_1N/RXN
B_2CEN/SCL	8	□	□	7	B_2P/SDP
GND	10	□	□	9	B_2N/SDN
B_3CEN	12	□	□	11	B_3P/TXEN
GND	14	□	□	13	B_3N/TXDIS
B_4CEN/ $\overline{\text{BUSP}}$	16	□	□	15	B_4P/TXP
GND	18	□	□	17	B_4N/TXN
NW_LED4A	20	□	□	19	NW_LED4B
NW_LED3A	22	□	□	21	NW_LED3B
NW_LED2A	24	□	□	23	NW_LED2B
NW_LED1A	26	□	□	25	NW_LED1B
GND	28	□	□	27	3V3
A_1CEN/SDA	30	□	□	29	A_1P/RXP
GND	32	□	□	31	A_1N/RXN
A_2CEN/SCL	34	□	□	33	A_2P/SDP
GND	36	□	□	35	A_2N/SDN
A_3CEN	38	□	□	37	A_3P/TXEN
GND	40	□	□	39	A_3N/TXDIS
A_4CEN/ $\overline{\text{BUSP}}$	42	□	□	41	A_4P/TXP
GND	44	□	□	43	A_4N/TXN
C_RX	46	□	□	45	C_TX
$\overline{\text{C_BUSP}}$	48	□	□	47	C_TXEN
GATE2	50	□	□	49	GATE1
GND	52	□	□	51	3V3

Figure 24.

4.1. Overview

Depending on network, the pins have different names and different functionality. Presented below is an overview of all pins except GND and 3V3. More detailed descriptions of the signals are described for each network/fieldbus version later in this section ([Network Connector \(page 45\)](#)).

Pin	Signal Name				
	Ethernet based networks, Copper	Ethernet based networks, fiber optic	DeviceNet	PROFIBUS	CC-Link
3	B_1P	B_RXP			
4	B_1CEN	B_SDA			
5	B_1N	B_RXN			
7	B_2P	B_SDP			
8	B_2CEN	B_SCL			
9	B_2N	B_SDN			
11	B_3P	B_TXEN			
12	B_3CEN				
13	B_3N	B_XDIS			
15	B_4P	B_TXP			
16	B_4CEN				
17	B_4N	B_TXN			
19	NW_LED4B	NW_LED4B	NW_LED4B	NW_LED4B	NW_LED4B
20	NW_LED4A	NW_LED4A	NW_LED4A	NW_LED4A	NW_LED4A
21	NW_LED3B	NW_LED3B	NW_LED3B	NW_LED3B	NW_LED3B
22	NW_LED3A	NW_LED3A	NW_LED3A	NW_LED3A	NW_LED3A
23	NW_LED2B	NW_LED2B	NW_LED2B	NW_LED2B	NW_LED2B
24	NW_LED2A	NW_LED2A	NW_LED2A	NW_LED2A	NW_LED2A
25	NW_LED1B	NW_LED1B	NW_LED1B	NW_LED1B	NW_LED1B
26	NW_LED1A	NW_LED1A	NW_LED1A	NW_LED1A	NW_LED1A
29	A_1P	A_RXP			
30	A_1CEN	A_SDA			
31	A_1N	A_RXN			
33	A_2P	A_SDP			
34	A_2CEN	A_SCL			
35	A_2N	A_SDN			
37	A_3P	A_TXEN			
38	A_3CEN				
39	A_3N	A_TXDIS			
41	A_4P	A_TXP			
42	A_4CEN				
43	A_4N	A_TXN			
45			C_TX	C_TX	C_TX
46			C_RX	C_RX	C_RX
47				C_TXEN	C_TXEN
48			C_BUSP_N		
49			GATE1	GATE1	GATE1
50			GATE2	GATE2	GATE2

At the moment the following copper wired Ethernet protocols are available: EtherNet/IP, PROFINET IRT, Ethernet POWERLINK, EtherCAT, Modbus-TCP, CC-Link IE Field and BACnet/IP. At the moment the following fiber optical Ethernet protocol is available: PROFINET IRT. The speed of all of these protocols are 100 Mb/s (using signal pairs 1-2 of each port), except CC-Link IE Field which is 1 Gb/s (using signal pairs 1–4 of each port).

The LED signals are active high and should be connected to respective LED via a resistor.

The pin types of the connector are defined in [PIN Types \(page 3\)](#). The pin types are specified for each network type on the following pages.

4.2. Power Supply Pins

Signal Name	Pin Type	Pin No.	Description
GND	Power	2, 6, 10, 14, 18, 28, 32, 36, 40, 44, 52	Ground Power and signal ground reference.
3V3	Power	1, 27, 51	3.3 V power supply.

4.3. How to Connect Unused Network Connector Pins

For Ethernet versions of the Anybus CompactCom B40-1 it is recommended to terminate Ethernet signals in the network interface if one of the Ethernet ports is unused. For the 10/100 Mb/s hardware version it is sufficient to terminate pair no. 1 and 2, for the port of concern, while for the 1 Gb/s hardware version this has to be done for pair no. 1, 2, 3, and 4.




Figure 25.

Unused fiber optic connector pins should be connected as follows:

- 100R between TXP and TXN
- 820R between SDN and 3V3, resulting in 2 V on SDN
- 1k5 between SDP and 3V3, resulting in 1.5 V on SDP Indicates that no signal is received. A signal amplitude of 0.5 V is appropriate.
- 4k7 between SCL and 3V3
- 4k7 between SDA and 3V3

Other network signals may be left floating when not used.

4.4. Ethernet Based Networks (Copper)

The industrial networks, that use Ethernet for communication, share the same hardware design. However, the firmware downloaded to the brick is different depending on network. Physically they use the same set of pins in a similar way. Bricks are available for the following Ethernet based networks: EtherNet/IP, EtherCAT, PROFINET, Ethernet POWERLINK, CC-Link IE Field and Modbus TCP.

The brick supports dual network ports, signal group A should be connected to the left port (port 1) and signal group B to the right port (port 2) on the connector board, looking at the front, see [Connector Board for Copper Based Ethernet \(page 62\)](#)

For EtherCAT, signal group A is used for the IN port and signal group B is used for the OUT port.

Signal Group	Signal Name	Pin Type	Pin	Description
B	B_1P	I/O	3	First pair, positive signal
	B_1CEN	Power	4	Center tap voltage for first pair
	B_1N	I/O	5	First pair, negative signal
	B_2P	I/O	7	Second pair, positive signal
	B_2CEN	Power	8	Center tap voltage for second pair
	B_2N	I/O	9	Second pair, negative signal
	B_3P	I/O	11	Third pair, positive signal. Used for Gigabit Ethernet.
	B_3CEN	Power	12	Center tap voltage for third pair. Used for Gigabit Ethernet.
	B_3N	I/O	13	Third pair, negative signal. Used for Gigabit Ethernet.
	B_4P	I/O	15	Fourth pair, positive signal. Used for Gigabit Ethernet.
	B_4CEN	Power	16	Center tap voltage for fourth pair. Used for Gigabit Ethernet.
	B_4N	I/O	17	Fourth pair, negative signal. Used for Gigabit Ethernet.
A	A_1P	I/O	29	First pair, positive signal
	A_1CEN	Power	30	Center tap voltage for first pair
	A_1N	I/O	31	First pair, negative signal
	A_2P	I/O	33	Second pair, positive signal
	A_2CEN	Power	34	Center tap voltage for second pair
	A_2N	I/O	35	Second pair, negative signal
	A_3P	I/O	37	Third pair, positive signal. Used for Gigabit Ethernet.
	A_3CEN	Power	38	Center tap voltage for third pair. Used for Gigabit Ethernet.
	A_3N	I/O	39	Third pair, negative signal. Used for Gigabit Ethernet.
	A_4P	I/O	41	Fourth pair, positive signal. Used for Gigabit Ethernet.
	A_4CEN	Power	42	Center tap voltage for fourth pair. Used for Gigabit Ethernet.
	A_4N	I/O	43	Fourth pair, negative signal. Used for Gigabit Ethernet.

4.5. Ethernet Fiber Optic Networks

Ethernet fiber optic networks use more or less the same pins as copper based Ethernet networks. The brick supports PROFINET fiber optic network (PROFINET IRT).

The brick supports dual network ports, signal group A is be connected to the left port (port 1) and signal group B to the right port (port 2) on the connector board, looking at the front, see [Connector Board for Fiber Optic Ethernet \(page 63\)](#).

If the Anybus CompactCom B40 connector board is not to be used, please study the design requirements for the Rx and SD channels, see [Rx Channel Design Requirements \(page 51\)](#) and [SD Channel Design Requirements \(page 52\)](#). Furthermore, fiber optic connectors without metal are preferred in order to minimize EMC disturbance.

Signal Group	Signal Name	Pin Type	Pin	Description
B	B_RXP	I	3	Rx, LVPECL positive signal
	B_SDA	I/O	4	SDA, I2C data
	B_RXN	I	5	Rx, LVPECL negative signal
	B_SDP	I	7	Signal Detect, LVPECL positive signal
	B_SCL	I/O	8	SCL, I2C clock
	B_SDN	I	9	Signal Detect, LVPECL negative signal
	B_TXEN	O	11	Tx enable TXEN is implemented as the inverse to TXDIS
	B_TXDIS	O	13	Tx disable
	B_TXP	O	15	Tx, LVPECL positive signal
	B_TXN	O	17	Tx, LVPECL negative signal
A	A_RXP	I	29	Rx, LVPECL positive signal
	A_SDA	I/O	30	SDA, I2C data
	A_RXN	I	31	Rx, LVPECL negative signal
	A_SDP	I	33	Signal Detect, LVPECL positive signal
	A_SCL	I/O	34	SCL, I2C clock
	A_SDN	I	35	Signal Detect, LVPECL negative signal
	A_TXEN	O	37	Tx enable TXEN is implemented as the inverse to TXDIS
	A_TXDIS	O	39	Tx disable
	A_TXP	O	41	Tx, LVPECL positive signal
	A_TXN	O	43	Tx, LVPECL negative signal

The differential signals Rx and Tx should be routed as differential pairs with a characteristic impedance of 100 Ω .

4.5.1. Rx Channel Design Requirements

The Rx channel is designed for an optical transceiver output that has an AC coupled 100 Ω differential signal with 100-1000 mV amplitude, e.g. LVPECL (low voltage positive emitter coupled logic). Each line is terminated with 50 Ω to a common point with a potential of 1.2 V on the brick.

If a transceiver with a DC coupled output is used, series capacitors are needed to obtain desired signal levels for the brick. Below is a figure describing three different options to connect a transceiver output to an Rx channel on the brick:




Figure 26.

The AC coupling capacitors typically have a value of 100 nF. Resistors draining bias current typically have a value of 150 Ω .

4.5.2. SD Channel Design Requirements

The SD (signal detect) channel is designed for a transceiver output that has a DC coupled differential output with 100-1000 mV amplitude. If a transceiver with LVTTTL/LVCMOS output is used, the signal needs to be conditioned using a few resistors, to obtain desired signal levels for the brick.

Each line is pulled to GND by a 1.27 kΩ resistor on the brick.

Even if the transceiver has a single ended output and the other line is at a fixed reference potential, it is recommended to route SDN and SDP side by side all the way to the signal conditioning resistors. This will give the interference, collected by the transmission line, common mode characteristics, and it can thus be ignored by the differential input, instead of becoming a differential mode interference that would corrupt the signal.

Below is a figure describing three different ways to connect a transceiver output to an SD channel of the brick:




Figure 27.

In case a and case b, additional pull-down resistors will be required if the LVPECL outputs require a certain bias current (> 1 mA) to function.

4.6. DeviceNet

The Anybus CompactCom B40-1 DeviceNet communication interface uses the following pins:

Signal Name	Pin Type	Pin	Description
C_TX	O	45	Tx
C_RX	I	46	Rx
C_BUSP_N	I	48	Bus power detection. Active low
GATE1	O	49	Low voltage MOS gate driver. For fieldbus isolated DC supply circuitry. The signals should preferably be routed to the connector board for future compatibility, but for DeviceNet, the isolated circuitry is generally supplied by the bus power.
GATE2	O	50	

For mechanical drawing of the applicable connector board see: [Connector Board for CC-Link and DeviceNet \(page 64\)](#)

4.7. PROFIBUS

The Anybus CompactCom B40-1 PROFIBUS DP-V1 communication interface uses the following pins:

Signal Name	Pin Type	Pin	Description
C_TX	O	45	Tx
C_RX	I	46	Rx
C_TXEN	O	47	TxEnable
GATE1	O	49	Low voltage MOS gate driver. For fieldbus isolated DC supply circuitry.
GATE2	O	50	Low voltage MOS gate driver. For fieldbus isolated DC supply circuitry.

For mechanical drawing of the applicable connector board see: [Connector Board for PROFIBUS and CANopen \(page 61\)](#) for information about the optional connector board.

4.8. CC-Link

The Anybus CompactCom B40-1 CC-Link communication interface uses the following pins:

Signal Name	Pin Type	Pin	Description
C_TX	O	45	Tx
C_RX	I	46	Rx
C_TXEN	O	47	TxEnable
GATE1	O	49	Low voltage MOS gate driver. For fieldbus isolated DC supply circuitry.
GATE2	O	50	Low voltage MOS gate driver. For fieldbus isolated DC supply circuitry.

For mechanical drawing of the applicable connector board see: [Connector Board for CC-Link and DeviceNet \(page 64\)](#) for information about the optional connector board.

4.9. LED Indicators

The Anybus CompactCom 40 series supports four bicolored LED indicators.

LED name	Pin no.	Signal Name	Default color	Default Functionality	
LED1	26	NW_LED1A	Green	Network status	
	25	NW_LED1B	Red		
LED2	24	NW_LED2A	Green	Module status	
	23	NW_LED2B	Red		
LED3	22	NW_LED3A	Green	All Industrial Ethernet Networks:	Link/Act for the network port (port A)
				Other:	Not used
	21	NW_LED3B	Yellow	EtherNet/IP, Modbus-TCP:	10 Mbit Link/Act for the network port (port A)
				Other:	Not used
LED4	20	NW_LED4A	Green	All Industrial Ethernet Networks:	Link/Act for the network port (port B)
				Other:	Not used
	19	NW_LED4B	Yellow	EtherNet/IP, Modbus-TCP:	10 Mbit Link/Act for the network port (port B)
				Other:	Not used

All LED outputs are active high and should be connected as shown in the picture below. The resistor values should be chosen to get even light between different LEDs.




Figure 28.

4.9.1. Ethernet, 1000 Mbit

For Gigabit Ethernet applications, another solution for connecting the LEDs is needed to obtain indications equal to the Anybus CompactCom M40. The solution, presented here, can be used for 10 and 100 Mbit applications as well. The table below shows how to interpret the LED indications in this case.



NOTE
Please note that the only Anybus CompactCom 40 that at this time supports 1 Gbit communication over Ethernet, is the Anybus CompactCom 40 CC-Link IE Field.

LEDxA	LEDxB	Indication
Low	Low	Off
Low	High	Yellow LED on for link detected, flickers to indicate 10 Mbit activity
High	Low	One green LED on for link detected, flickers to indicate 100 Mbit activity
High	High	Two green LEDs on for link detected, flickers to indicate 1 Gbit activity

All LED outputs are active high and should be connected as shown in the picture below.




Figure 29.

5. EMC

This section offers information, necessary when designing in an Anybus CompactCom B40-1, to ensure sufficient performance related to EMC. However, an engineering assessment is always needed to ensure the quality. HMS Industrial Networks does not leave any guarantees, but provides relevant information to the customers.


5.1. General

When working with a design in relation to EMC, it is recommended to always aim for good signal integrity, since this is highly related to the EMC. For power, this means solid planes for both power and GND together with good decoupling between the planes. As the quality of the power is of great importance, it is important to perform sufficient verifications during the design process to ensure this. This is also true for signals, where good signal integrity most likely results in good EMC performance. There should always exist good connection to a reference plane without any obstacles for the return current. Traces should also be kept short, with as few board and cable transitions as possible, since every transition will have a negative impact on the signal integrity.

- If the Anybus CompactCom B40 is implemented in a metal chassis, a low inductive connection between the RJ45 shield and chassis is required.
 - If a directly grounded shield is acceptable, the RJ45 shield should be directly connected to the chassis with a connection as short and wide as possible.
 - If the risk of ground currents via a directly grounded shield is not acceptable, a 1nF capacitor must be installed in the connection between the RJ45 shield and the chassis. The connection should be as short and wide as possible.
- A low inductive connection is required between FE and GND (signal ground), close to the transformer.
 - For products in which chassis ground and signal ground are connected, or where chassis ground is non-existent, FE on the transformers secondary side can be connected to GND on the transformers primary side, via a shared plane.
 - For products in which chassis ground and signal ground are separated, one or more 1nF capacitors are needed for the connection between FE on the transformers secondary side and the GND on the transformers primary side. The connection should be made using low inductive planes, can be combined with a 1MΩ bleeding resistance.


Considering the host application connector, different protocols are more sensitive to interference than others. E.g. try to avoid using parallel and RMII interface in the design, if the recommendations in this section cannot be followed or if the risk of interference is high. To ensure stability, there has to be a sufficient separation on the host board between a parallel interface and an RMII interface.

Layout examples



Please note that Bob-Smith is not visualized in this example, but is required for good EMC performance.

Figure 30. Custom Implementation without Connector Board



FE and GND planes must be connected, see [Custom Implementation without Connector Board \(page 57\)](#) for how it can be done using a capacitor and a resistor.

The connector board stand-off should be conductive and connected to FE.

Figure 31. Using a Connector Board

Ideally, the planes (shield, FE, GND) should overlap to minimize current loops, hence also minimizing inductance. The purpose of the capacitors is to keep the common mode voltage across the transformer as low as possible, and also providing a good current path to system ground. The value of the capacitors must be chosen in relation to the DCMR¹ and CMR² values of the transformer, this is especially important for immunity testing, such as ESD. In most cases 1nF is a reasonable starting point.

Shield, FE, and GND planes should ideally be regularly shaped and as large as possible. As a rule of thumb, the length/width relationship of the planes should not exceed 5/2.

¹DCMR is defined as the rejection ratio between the common-mode and the differential-mode voltage.

²Common mode rejection ratio.

5.2. Bulk and Decoupling

Recommendations regarding bulk and decoupling capacitors is presented in [Bypass Capacitance \(page 80\)](#).

The capacitors have impact on the power quality at the Anybus CompactCom board, but are also of importance in relation to EMC immunity. These general recommendations should be evaluated for every design. The values may also need to be adjusted in relation to power consumption, power quality on the main board, and the layout of the main board.

5.3. Reset Signal

There are several aspects to consider when routing the reset signal for the Anybus CompactCom. Requirements for rise and fall time, but also the relation between the power up and the reset signal are described in [RESET \(Reset Input\) \(page 16\)](#). These requirements must be met in all designs to ensure stability. If the reset signal has a long trace or if there is any other aspect that has a negative impact on the signal integrity, an RC filter may be required. To minimize the risk of EMC problems, it is possible to add footprints for a RC-filter in advance and evaluate the need before it becomes a problem during any certification. When designing the filter, all timing aspects must be considered, so that the timing requirements in [RESET \(Reset Input\) \(page 16\)](#) are fulfilled.

6. Black Channel/Safety Interface

The black channel is a transportation mechanism for safety related protocol extensions over a nonsafe communication media. The safety layer performs safety related transmission functions and checks on the communication to ensure that the integrity of the link meets the requirement for SIL 3, cat4/PL e. The black channel can be seen as a virtual link between the safety layers of the devices.




Figure 32.

The IXXAT Safe T100 is a precertified embedded safety option module which provides device manufacturers with an easy and cost efficient way to integrate conformant safe I/O signals into standard automation devices. It connects via its serial black channel interface to the Anybus CompactCom. The safety module provides digital safe I/O signals that can be controlled via the network and that can be directly connected to the safety functions of an automation device. Other standard safety modules can also be used to provide a safety communication interface for the Anybus CompactCom 40 series.

The same serial interface is used both for serial download and for safety communication. Please take this in account when implementing the use of a safety module or Black Channel.

Appendix A. Mechanical Specification

3D models for the CompactCom 40 are available on the respective product web pages, see www.hms-networks.com.

All dimensions are in millimeters, tolerance ± 0.10 mm, unless otherwise stated.

1. Anybus CompactCom B40-1

The dimensions for the Anybus CompactCom B40-1 are given in the picture below.




Figure A.1.

2. Connector Board for PROFIBUS and CANopen

The connector board for the PROFIBUS and the CANopen network interfaces carry a D-sub connector.



IMPORTANT

If the connector board is mounted in an environment that is subject to vibration, please make sure to secure the network cable in such a manner, that the vibrations will not harm the D-sub connector.




Figure A.2.

3. Connector Board for Copper Based Ethernet

The connector board for the copper based Ethernet network interfaces carries two RJ45 connectors.




Figure A.3.

4. Connector Board for Fiber Optic Ethernet

The connector board for the fiber optic Ethernet network interface carries two fiber optic transceivers.




Figure A.4.

5. Connector Board for CC-Link and DeviceNet

The connector board for the CC-Link and the DeviceNet network interfaces carry a pluggable screw terminal (5.08 mm)




Figure A.5.

6. Footprints

6.1. Anybus CompactCom B40-1

The Anybus CompactCom B40-1 is connected to the host application board through the host application interface connector and a network interface connector. The footprint for the Anybus CompactCom B40-1 is shown in the picture below.




Figure A.6.

See [Assembly \(page 68\)](#) for suggested components.

6.2. Network Connector Board

The network connectors are mounted on a separate connector board. The footprint for a connector board is shown in the figure below. This footprint is the same for all connector boards.




Figure A.7.

The fastening screw must be connected to the functional earth (FE) of the host application.

See [Assembly \(page 68\)](#) for suggested components.

7. Height Restrictions

All dimensions are in millimeters.




Figure A.8.



NOTE

The maximum height occupied by onboard components of the Anybus module is 8 mm. To ensure isolation, it is recommended to add an additional 2.5 mm on top of these dimensions.

8. Front Plate Restrictions

Customer applications that have a front plate with hole(s) for accessing the connector(s) of a connector board, must have the front plate placed at least 0.5 mm away from the connector board edge and must not reach further than 2.5 mm away from the connector board edge.




Figure A.9.

9. Assembly

The Anybus CompactCom B40-1 and the connector board are mounted separately on to the host application board. The connector board has to be secured using a screw, joining FE (functional earth) on the connector board to FE on the host application board. The screw holes of the Anybus CompactCom B40-1 are not connected to FE, but to GND. If suggested components are used, the Anybus CompactCom B40-1 can be mounted without screws in a low vibration environment, see [Shock and Vibration \(page 70\)](#) for more information.

The Anybus CompactCom B40-1 can either be connected to the application board using headers, or soldered directly to the host application PCB.




Figure A.10.

Suggested components		
Header	Application interface	Samtec CLP-128-02-L-D (56 pin)
	Network interface	Samtec CLP-126-02-L-D (52 pin)
Stand-off (M3)	Pemnet SMTSO-M3-4-ET	

The screw standoffs are typically 4 mm tall. If the Anybus CompactCom B40-1 and connector board are to be soldered directly to the host application board, standoffs should be 2 mm tall. Outer diameter may be 6 mm max. The standoffs should not extend outside the screw mount pads.

Recommended torque is 0.2 Nm. Locking paint can be used to secure the screws against loosening.




Figure A.11.

Appendix B. Technical Specification

1. Environmental

1.1. Operating

-40 to 85° C (-40 to 185° F)

1.2. Storage

-40 to 85°C (-40 to 185° F)

1.3. Humidity

5 to 95% non-condensing

2. Shock and Vibration

2.1. Shock

The Anybus CompactCom B40-1 and the associated connector boards are tested according to IEC 68–2–27

- half-sine 30 g, 11 ms, 3 positive and 3 negative shocks in each of three mutually perpendicular directions

2.2. Sinusoidal Vibration

The Anybus CompactCom B40-1 is tested according to IEC 68–2–6

Frequency range:	10–500 Hz
Amplitude 10–49 Hz:	0.35 mm
Acceleration 50–500 Hz	5 g
Sweep rate:	1 oct/min
	10 double sweep in each of the three mutually perpendicular directions

3. Electrical Characteristics



IMPORTANT
Failure to follow the requirements may lead to permanent hardware damage.

It is recommended for Anybus CompactCom B40-1 users to make sure that each signal controlling the Anybus CompactCom B40-1 has a drive strength enough to fulfill level and timing constraints even if the signal is loaded with 20 pF in parallel with 2.2 kΩ to GND or 3V3.

3.1. Operating Conditions

Symbol	Parameter	Pin Types	Conditions	Min.	Typ.	Max.	Unit
3V3	Supply Voltage (DC)	PWR	-	3.15	3.30	3.45	V
	Ripple (AC)			-	-	± 100	mV
GND	Ground reference			0.00	0.00	0.00	V
I _{IN}	Current consumption (also including network interfaces and network status LEDs)		Class A	-	-	250	mA
			Class B	-	-	500	mA
			Class C	-	-	1000	mA
V _{IH}	Input High Voltage	I, BI	-	2.0	-	3.45	V
V _{IL}	Input Low Voltage			-0.3	-	0.8	V
I _{OH}	Current, Output High	O, BI	-	-8.0	-	8.0	mA
I _{OL}	Current, Output Low						
V _{OH}	Output High Voltage						
V _{OL}	Output Low Voltage		I _{OH} = -4mA	2.4	-	-	V
			I _{OL} = 4mA	-	-	0.4	V
I _{OH} (NW_LEDx)	Output Current, network LEDs	O				20	mA

I= Input, CMOS (3.3V)

O= Output, CMOS (3.3V)

BI= Bidirectional, Tristate

PWR= Power supply inputs

4. Regulatory Compliance

4.1. EMC Compliance (CE)

Since the Anybus CompactCom is considered a component for embedded applications it cannot be CE-marked as an end product.

However the Anybus CompactCom 40 family is pre-compliance tested in a typical installation providing that all modules are conforming to the EMC directive in this installation.

The EMC pre-testing has been conducted according to the following standards:

Emission: EN61000-6-4	EN55016-2-3 Radiated emission
	EN55022 Conducted emission
Immunity: EN61000-6-2	EN61000-4-2 Electrostatic discharge
	EN61000-4-3 Radiated immunity
	EN61000-4-4 Fast transients/burst
	EN61000-4-5 Surge immunity
	EN61000-4-6 Conducted immunity

Since all Anybus CompactCom B40-1 modules have been evaluated according to the EMC directive through above standards, this serves as a base for our customers when certifying Anybus CompactCom B40-1 based products.

4.2. UL/c-UL Compliance



All members in the Anybus CompactCom B40 series are UL Recognized Components.

Appendix C. How to Inactivate Ethernet Port 2 (Industrial Ethernet)

It is possible to inactivate Ethernet Port 2 on the Anybus CompactCom B40-1 for select networks. For more information on what networks support this feature, see Anybus CompactCom 40 Software Design Guide.

To inactivate Ethernet Port 2:

- Do not connect signal group B

**NOTE**

For signal termination recommendations, see [How to Connect Unused Network Connector Pins \(page 48\)](#).

- Do not connect signals LED4A/B

For descriptions of signals see:

- [Overview \(page 47\)](#)
- [Ethernet Based Networks \(Copper\) \(page 49\)](#)
- [LED Indicators \(page 54\)](#)

Appendix D. Implementation Examples

1. General

In this appendix HMS Industrial Networks provides examples of possible implementations for the Anybus CompactCom B40-1 series.



IMPORTANT

There are many different processors with different functionality available on the market today. The implementations in this appendix are to be regarded as examples that are designed for one single type of processor. Other hardware interfaces may require adjustments for timing, different functionality etc. It is important to fully understand the interface to take correct design decisions in order to obtain a stable and reliable design.

2. SPI

This example shows a design intended for an SPI implementation.




Figure D.1.

If LEDs are to be used in the host application, please refer to [Network Status LED Outputs \(LED\[1A...4B\]\)](#) (page 77), for guidelines on how to connect the LED outputs.

For information on how to handle unused pins, see [Pin Usage in SPI Mode](#) (page 28).

3. 16-bit Parallel

This example shows a design intended for 16-bit parallel mode.




Figure D.2.

If LEDs are to be used in the host application, please refer to [Network Status LED Outputs \(LED\[1A...4B\]\)](#) (page 77), for guidelines on how to connect the LED outputs. In 16-bit parallel mode it is not possible to use these outputs for LEDs. The network status LED signals are always present on the network interface connector, see [Network Connector](#) (page 45).

For information on how to handle unused pins, see [Pin Usage in 16-bit Parallel Mode](#) (page 23).

4. 8-bit Parallel

This example shows a design intended for 8-bit parallel mode.




Figure D.3.

If LEDs are to be used in the host application, please refer to [Network Status LED Outputs \(LED\[1A...4B\]\)](#) (page 77), for guidelines on how to connect the LED outputs.

For information on how to handle unused pins, see [Pin Usage in 8-bit Parallel Mode](#) (page 20).

5. Serial

This example shows a design intended for an implementation with serial communication.




Figure D.4.

For information on how to handle unused pins, see [Pin Usage in Serial Mode \(page 42\)](#).

6. Network Status LED Outputs (LED[1A...4B])

All network status LED signals are easily available on the network interface connector. It is recommended to use these signals when the network status is to be displayed. However they are also available on the host interface connector (LED[1A...4B]).

The LED[1A...4B] outputs can be used to relay the network status LEDs to elsewhere on the host application. This is possible in all modes except 16-bit parallel mode, where these pins are used for data (D8...D15).

Note that it is the responsibility of the host application to ensure that each LED output is connected to a LED of the correct color (it is possible to retrieve this information from the LED status register or from the Anybus Object (01h); consult the Anybus CompactCom Software Design Guide for more information). For more information, see [LED Interface / D8–D15 \(Data Bus\) \(page 12\)](#).

The outputs are unbuffered, and are not recommended for driving LEDs directly. Please consult the image below for guidelines on how to connect the LED outputs.




Figure D.5.



NOTE

These pins can not be used for LEDs in 16-bit parallel mode, as the pins in that case are used for data. All network status LED signals are present on the network interface connector, and can be connected from there.

7. Power Supply Considerations

7.1. General

The Anybus CompactCom 40 platform in itself is designed to be extremely power efficient. The exact power requirements for a particular networking system will however vary a lot depending on the components used in the actual bus circuitry.

While some systems usually require less than 250 mA of supply current at 3.3 V, some high performance networks, or networks which require the use of legacy ASIC technology, will consume up to 500 mA, or in rare cases even as much as 1000 mA.

As an aid when designing the power supply electronics, the networks have been divided into classes based on their power consumption as follows.

- Class A: less than 250 mA
- Class B: up to 500 mA
- Class C: up to 1000 mA

Please note that the power supply classifications take into account that the power budget is shared with a full fieldbus circuitry, e.g. the appropriate connector board and NW_LEDs with maximized consumption (20 mA each).

The following table lists the currently supported networking systems and their corresponding class.

Network	Class A	Class B	Class C
DeviceNet		X	
PROFIBUS	X		
CANopen	X		
EtherCAT		X	
PROFINET 2-Port		X	
PROFINET Fiber Optic 2-Port			X
EtherNet/IP 2-Port		X	
Ethernet POWERLINK		X	
Common Ethernet		X	
CC-Link		X	
Modbus-TCP 2-Port		X	
CC-Link IE Field			X
BACnet/IP		X	

A power supply designed to fulfill Class A requirements (250 mA), will be able to support all networks belonging to class A, but none of the networks in Class B and C.

A power supply designed to fulfill Class C requirements, will be able to support all networks.

7.2. Bypass Capacitance

The power supply inputs must have adequate bypass capacitance for high-frequency noise suppression. It is therefore recommended to add extra bulk capacitors near preferably all the power supply inputs (or at least two):

Reference	Value (Ceramic)
C1	10 μ F / 6.3 V




Figure D.6.

7.3. 3.3 V Regulation

The following example uses the LT1767 from Linear Technology to provide a stable 3.3 V power source for the module. Note that all capacitors in this example are of X7R ceramic type.




Figure D.7.



NOTE
For detailed information regarding this example, consult the data sheet for the LT1767 (Linear Technology).

Appendix E. Design Examples, Network Interface

If the optional connector board is used, the signals from the network interface connector of the brick can be routed directly to the corresponding pins of the connector on the connector board. Section [PCB Layout \(page 83\)](#) shows an example PCB layout for this case.

This appendix also contains typical examples, of how to design the network interface, if the optional connector board is not to be used. See [Network Interface Examples \(page 84\)](#).

1. Recommendations

- The longer the distance between the Brick and the Connector board, the more important it is that single-ended signals as well as signal pairs are separated from other signals and signal pairs to maintain good signal integrity.
- All conductors should have a tighter coupling to a continuous ground plane than to any adjacent conductor (even to the partner signal of a signal pair). All signal pairs should have a differential impedance of $100\ \Omega \pm 10\%$.

It is not recommended to separate network circuitry, e.g. Connector board, and Brick more than 400 mm. The distance should be kept shorter if the signals are adjacent to other interfering circuitry. Radiated interference from the signals between the Connector board and Brick may need to be taken care of by e.g. a metallic housing or encapsulating PCB copper planes if the routing distance is long.

- If a design will be used for Gigabit Ethernet applications, the following has to be fulfilled:
 - The maximum difference in length, between signal pairs (1 - 4) in the design must not exceed 6.7 mm.
 - The maximum difference in length, between the two signals in a signal pair must not exceed 0.25 mm from Phy to Gigabit Magnetics and 0.25 mm from Gigabit Magnetics to the Ethernet connector.




Figure E.1.

- To avoid B40-1 connector pins penetrating the solder mask under the headers on the carrier board, thus creating short circuits, the following is recommended:
 - either use headers that are higher than 2.5 mm,
 - or do not design any vias or traces on top side of the PCB, where there is any risk for short circuits, see figure in section [PCB Layout \(page 83\)](#).
- Minimum recommended power rating for termination/grounding resistors is 1/16 W.
- The network interfaces that require an isolated power supply can be powered using a discrete DC/DC converter layout, as demonstrated in the example schematics. With this layout the transformer must fulfill the following requirements:
 - 1:2.1 turns ratio
 - 500 kHz switching frequency
 - The transformer shall be able to deliver at least 100 mA on the network interface side without saturating, at Anybus CompactCom min/max supply voltage, and at the relevant min/max ambient temperature that is applicable
 - Under the above circumstances, the transformer and rectifier output voltage must allow the regulator to keep the 5V rail inside a $\pm 5\%$ tolerance

It is also possible to power the network interface from an existing isolated power supply, if one is available, or from an off-the-shelf integrated DC/DC converter. In either case the applicable requirements above must be fulfilled.

2. PCB Layout

The pin headers of the Anybus CompactCom B40-1 have pins which are 2.3 mm tall nominally, but to avoid risk of short circuit when the pin length is in the upper tolerance region, it is suggested to have via/route keepouts on the PCB top layer, in between the pad rows, as the figure shows, unless a receptacle taller than 2.6 mm is used.




Figure E.2.

3. Network Interface Examples

This section contains typical examples, of how to design the network interface, if the optional connector board is not to be used. Examples are given for the usual network connectors as well as for M12 connectors making a higher IP rating possible.




IMPORTANT


The schematics in this chapter contains the schematic-level items that are required for a basic implementation of specific networks. However the examples are not intended to cover aspects like 'best practice' for board layout and routing with a certain physical layer, implementation of optional network-specific features, regulatory compliance for EMC and isolation, and similar. It is assumed that an implementer has acquired the relevant knowledge about each such aspect by consulting applicable standards, specifications, and similar before laying out and routing their board.

Example Schematics	Brick	Comments
10 and 100 Mbit Ethernet Network Interface (Copper)	EtherNet/IP EtherCAT Modbus TCP Common Ethernet POWERLINK PROFINET IRT BACnet/IP	All bricks for 100 Mb/s Ethernet based protocols, running on copper wire, use the same hardware. Ethernet trafo example: 7490100111A (Würth Elektronik Gmbh) RJ45 connector example: SS-60300-032 (Bel Stewart)
100 Mbit Ethernet Network Interface (Fiber Optic)	PROFINET IRT	-
10 and 100 Mbit Ethernet Network Interface (M12)	EtherNet/IP EtherCAT Modbus TCP Common Ethernet POWERLINK PROFINET IRT BACnet/IP	All bricks for 100 Mb/s Ethernet based protocols, running on copper wire, use the same hardware. Ethernet trafo example: 7490100111A (Würth Elektronik Gmbh)
10, 100 and 1000 Mbit Ethernet Network Interface	CC-Link IE Field	RJ45 connector example: SS-60300-032 (Bel Stewart)
PROFIBUS	PROFIBUS	-
PROFIBUS (M12)	PROFIBUS	-
DeviceNet	DeviceNet	-
DeviceNet (M12)	DeviceNet	-
CC-Link	CC-Link	-
CANopen	CANopen	-


Design Example
10 and 100 Mbit Ethernet
Network Interface
with RJ-45 connectors




Design Example
Ethernet Fibre Optics
Network Interface




Design Example
10 and 100 Mbit Ethernet
Network Interface
with M12 connectors



Design Example 10, 100 and 1000 Mbit Ethernet Network Interface




- Notes:
- 1, 2) Center tap capacitors are placed close to respective transformer.
 - 3, 4) Four differential pairs with impedance and length matching. Differential impedance is 100 ohm and length matching within 0,25 mm between and totally from J1 to TR1 and from TR1 to J2.
 - 5, 6) Four differential pairs with impedance and length matching. Differential impedance is 100 ohm and length matching within 0,25 mm between and totally from J1 to TR2 and from TR2 to J3.
 - 7, 8) Pairs A, B, C and D are length matched in between. Max length difference between the longest and the shortest pair is 6,7 mm from J1 to J2.
 - 9, 10) Pairs A, B, C and D are length matched in between. Max length difference between the longest and the shortest pair is 6,7 mm from J1 to J3.
 - 11, 12) No routing under magnetics.
 - 13, 14) Routing from shield to PE kept short to avoid disturbances.




Design Example PROFIBUS Network Interface with D-sub connector


Design Example
PROFIBUS
Network Interface
with M12 connectors




Design Example
DeviceNet
Network Interface
with open style connector




Design Example
DeviceNet
Network Interface
with M12 connectors



Design Example
CC-Link Network Interface



Design Example CANopen Network Interface



NOTES:
1) Discharge resistor